


Series CDT and CDTR Wall Mount Carbon Dioxide/ Temperature Transmitter

Specifications - Installation and Operating Instructions





Series CDT and CDTR Wall Mount Carbon Dioxide and Temperature Transmitters accurately monitor the ${\rm CO_2}$ concentration and temperature in schools, office buildings, and other indoor environments to help achieve LEED® certification. Additionally, the Series CDTR also measures ambient relative humidity. For increased sensor life, a single-beam dual-wavelength non-dispersive infrared (NDIR) sensor is used to automatically correct the measurement in both occupied and unoccupied buildings against aging effects. The single-beam dual-wavelength sensor technology provides the highest level of accuracy compared to Automatic Baseline Correction methods, which can unintentionally shift the calibration based on ${\rm CO_2}$ levels and barometric pressure conditions. In order to achieve a higher level of accuracy, the Series CDT includes digital barometric pressure adjustment and the ability to field-calibrate the sensor.

Universal outputs allow users to select the transmitter output to be 4 to 20 mA, 0 to 5 VDC, or 0 to 10 VDC to work with virtually any building management controller. An optional relay with user adjustable set points can be used to control exhaust fans, open actuated windows or dampers, or signal a light or horn.

For applications that require visual indication, the Series CDT and CDTR can be ordered with an integral LCD display or the Model A-449 remote LCD display that can plug into the mini-connector port on the side of the transmitter. Both the CDT and CDTR can be configured to display temperature only, $\rm CO_2$ only, or $\rm CO_2$ and temperature together. The CDTR can also display relative humidity or $\rm CO_2$ and relative humidity together. Push buttons are standard on the transmitters for access to the menu structure, but the transmitter can be ordered without the buttons. To prevent tampering, the action of the buttons can be locked out using an internal jumper selection. Menu items that can be accessed include: engineering units, relay output set points, display configuration, transmitter output scaling, ambient barometric pressure and field calibration of the transmitter.

Single-beam dual-wavelength sensor advantages:

- · Automatically corrects for aging effects in occupied and unoccupied buildings
 - Perfect for hospitals and manufacturing plants that are occupied 24 hours per day
- · Measures actual unfiltered light intensity directly
 - Eliminates error from incorrect assumptions of gas concentration in theoretical logic assumption methods

SPECIFICATIONS

Range:

CO₂: 0 to 2000 or 0 to 5000 ppm (depending on model);

RH: 0 to 100%;

Temperature: 32 to 122°F (0 to 50°C); **Accuracy:** ±40 ppm + 3% of reading; ±2% (RH). **Temperature Dependence:** ±8 ppm / °C at 1100 ppm.

Non-Linearity: 16 ppm.

Pressure Dependence: 0.13% of reading per mm of Hg. Response Time: 2 minutes for 99% step change. Temperature Limits: 32 to 122°F (0 to 50°C). Humidity Limits: 10 to 95% RH (non-condensing). Power Requirements: 16 to 35 VDC / 19 to 28 VAC. Power Consumption: Average: 2 watts; Peak: 3.75 watts.

Sensor: Single-beam, dual-wavelength NDIR.

Output:

Current: 4 to 20 mA (max 500 Ω);

Voltage: 0 to 5 VDC or 0 to 10 VDC (min 500 Ω);

Relay: SPST NO 2A @ 30 VDC;

RTD or thermistor per r-t curves (depending on model).

Weight: 5.6 oz (158.8 g).

INSTALLATION

▲ WARNING

Disconnect power supply before installation to prevent electrical shock and equipment damage.

Make sure all connections are in accordance with the job wiring diagram and in accordance with national and local electrical codes. Use copper conductors only.

CAUTION

Use electrostatic discharge precautions (e.g., use of wrist straps) during installation and wiring to prevent equipment

damage.

CAUTION

Avoid locations where severe shock or vibration, excessive moisture or corrosive fumes are present..

CAUTION

Do not exceed ratings of this device, permanent damage not covered by warranty may result.

NOTICE

Upon powering the transmitter, the firmware version will flash on the display. A warm up period of 30 minutes is required for the transmitter to adjust to the current CO₂ concentration.

NOTICE

Self calibration feature of the transmitter requires exposure to normal outdoor equivalent carbon dioxide level once every thirty

days.

LEED® is a registered trademark of the U.S. Green Building Council.

Phone: 219/879-8000 Fax: 219/872-9057

www.dwyer-inst.com e-mail: info@dwyer-inst.com




Figure 1: Removal Of Cover From Back Plate

MOUNTING

- 1. Push tab on bottom of cover and lift cover from back plate (See Figure 1).
- 2. Select the mounting location, away from diffusers, lights or any external influences
- Mount transmitter on a vertical surface to a standard electrical box using the two #6 M2C type screws provided.
- 4. Pull wires through sub base hole and make necessary connections.
- 5. Reattach cover to base plate.

WIRING

Use maximum 18 AWG wire for wiring to terminals. Refer to Figure 5 for wiring information




Figure 2: Diagram Of Circuit Board

Selection of Current and Voltage Outputs

Prior to wiring, verify that the current/voltage selection jumpers (PJ1, PJ2, and PJ5) are set to the desired output type. Refer to Figure 2 to locate the selection jumpers. See Figure 3 for diagram of the current/voltage selection jumper. For voltage output selection, the output can be 0 to 10 VDC, 0 to 5 VDC, 2 to 10 VDC or 1 to 5 VDC. See Figure 4 for the type of voltage output selection jumper (PJ5).




FIGURE 3: Current/Voltage Output Selection Jumper (PJ1 And PJ2)









Figure 4: Output Range Selection Jumper (PJ5)

Current / Voltage Outputs

On the CDT, the transmitter may be wired for current or voltage output for both carbon dioxide and temperature. On the CDTR, the transmitter may be wired for current or voltage output for both carbon dioxide and humidity. The transmitter can be powered with either 16 to 35 VDC or 19 to 28 VAC. Wire the transmitter according to Figure 5.

NOTICE

Optional relay can be used as either a dry contact or low voltage switched circuit up to 2 A at 30 VDC.




Figure 5: Active Output Wiring Diagram

Remote Display

For models that are ordered without an integral LCD display, remote display Model A-449 can be used to display the temperature, humidity, and carbon dioxide. The mini USB plug of the remote display plugs into the receptor on the side of the housing. After a short warm up time, the display will begin to show the current temperature and carbon dioxide measurements unless configured by the user to show humidity and carbon dioxide, only temperature, only humidity, or only carbon dioxide.

EDITING MENU PARAMETERS



Figure 6: Menu Lockout Jumper

Before any adjustment can be made to the transmitter, the Menu Lockout Jumper (PJ4) must be set to the "On" position (See Figure 6).

ACCESSING MENU PARAMETERS

- Step 1: To enter the menu structure, press △ and ▽ simultaneously for 5 seconds (display will show RON parameter).
- Step 2: Press \triangle or ∇ to cycle between menu items.
- Step 3: Press to edit the value for the displayed menu item (SET will appear on display).
- Step 4: Press (\triangle) or (∇) to adjust the value of the menu item.
- Step 5: Press _______to save the changes (SET will disappear).
- Step 6: Repeat Steps 2 through 5 for each of the parameters.
- Step 7: To exit the menu at any time, press and hold △ and ▽ simultaneously for 5 seconds or wait 10 seconds without pushing any buttons.

Menu Descriptions

RON Relay on set point

Sets the CO₂ concentration which the optional relay is energized.

Low limit: 0 PPM Factory setting: 1000 PPM

High limit: 2000/5000 PPM (depending on model)

ROF Relay off set point

Sets the CO_2 concentration which the optional relay is de-energized. Setting value lower than RON provides direct action for detecting high concentrations of CO_2 . Setting value higher than RON provides indirect action for detecting low concentrations of CO_2 . On the LCD display will be lit to indicate when the relay is energized.

Low limit: 0 PPM Factory setting: 950 PPM

High limit: 2000/5000 PPM (depending on model)

DSP Display configuration

Determines the LCD display configuration during normal operation. The LCD display can indicate the $\rm CO_2$ concentration, temperature, relative humidity (CDTR only) and $\rm CO_2$ concentration combined with temperature or relative humidity (CDTR only).

CH CO₂ concentration and relative humidity (CDTR only)

CT CO₂ concentration and temperature

C CO₂ concentration only T Temperature only

H Relative humidity only (CDTR only)

UNI Units selection

Temperature and barometric pressure measurements can be displayed in US engineering units or SI engineering units. The factory default is to display US engineering units.

US units °F for temperature and in Hg for barometric pressure SI units °C for temperature and hPa for barometric pressure

COL CO2 low output range

Sets the CO₂ concentration for the lowest output (4 mA or 0 VDC).

Low limit: 0 PPM Factory setting: 0 PPM

High limit: 2000/5000 PPM (depending on model)

COH CO2 high output range

Sets the CO_2 concentration for the highest output (20 mA, 5 VDC or 10 VDC). When COH is set above COL, the transmitter is direct acting and the output will increase with an increase in CO_2 level. When COH is below COL, the transmitter is reverse acting and the output will increase with a decrease in CO_2 level.

Low limit: 0 PPM

Factory setting: 2000/5000 PPM (depending on model) High limit: 2000/5000 PPM (depending on model)

TOL Temperature low output range (CDT with active temperature only) Sets the temperature for the lowest output (4 mA or 0 VDC).

Low limit: 32.0°F / 0.0°C Factory setting: 32.0°F / 0.0°C High limit: 122.0°F / 50.0°C

TOH Temperature high output range (CDT with active temperature only)

Sets the temperature for the highest output (20 mA, 5 VDC or 10 VDC). When TOH is set above TOL, the transmitter is direct acting and the output will increase with an increase in temperature. When TOH is below TOL, the transmitter is reverse acting and the output will increase with a decrease in temperature.

Low limit: 32.0°F / 0.0°C Factory setting: 122.0°F / 50.0°C High limit: 122.0°F / 50.0°C

HOL Humidity low output range (CDTR only)

Sets the temperature for the lowest output (4 mA or 0 VDC).

Low limit: 0.0% Factory setting: 0.0% High limit: 100.0%

HOH Humidity high output range (CDTR only)

Sets the temperature for the highest output (20 mA, 5 VDC or 10 VDC). When HOH is set above HOL, the transmitter is direct acting and the output will increase with an increase in temperature. When HOH is below HOL, the transmitter is reverse acting and the output will increase with a decrease in temperature.

Low limit: 0.0% Factory setting: 100.0% High limit: 100.0%

BAR Barometric pressure

Sets the typical barometric pressure for the location where the transmitter is mounted. The factory setting is for standard pressure at sea level. Adjusting the barometric pressure gives a more accurate measurement, especially at higher elevations. Refer to the elevation charts in Figure 9 for typical barometric pressures at a given elevation.

Low limit: 20.0 in Hg / 600 hPa Factory setting: 29.9 in Hg / 1013 hPa High limit: 32.0 in Hg / 1100 hPa

CAL Calibration

Calibrates the carbon dioxide sensor to a known gas value. Read calibration instructions before using this feature. Hold () for 5 seconds.

CALIBRATING SENSOR

- Step 1: Remove the cover as shown in Figure 1.
- Step 2: Slide the calibration tubing through the slots on the back plate and attach to one of the nipples on the CO₂ sensor (See Figure 7).
- Step 3: Carefully re-attach the cover to the back plate without pinching the tubing between the back plate and the cover.
- Step 4: Follow the steps in the accessing parameter section to access the calibration parameter (CAL).
- Step 5: Press the button.
- Step 6: Flow zero reference gas at 0.3 SLPM for 5 minutes.
- Step 7: Press and hold the 🔻 button for 3 seconds.
- Step 8: Flow the full scale reference gas at 0.3 SLPM for 5 minutes.
- Step 9: Press and hold the (\triangle) button for 3 seconds.
- Step 10: Exit the parameter menu.
- Step 11: Remove cover as shown in Figure 1.
- Step 12: Remove tubing from sensor and re-attach the gas nipple cover to the sensor.
- Step 13: Re-attach the cover to the back plate.

MAINTENANCE/REPAIR

Upon final installation of the Series CDT and CDTR, no routine maintenance is required. The Series CDT and CDTR are not field serviceable and should be returned if repair is needed. Field repair should not be attempted and may void warranty.

WARRANTY/RETURN

Refer to "Terms and Conditions of Sales" in our catalog and on our website. Contact customer service to receive a Return Goods Authorization number before shipping the product back for repair. Be sure to include a brief description of the problem plus any additional application notes.




Figure 7: Calibration

Series	CDT	-2	W	4	4	-LCD	Example: CDT-2W44-LCD	
Range		2					0 to 2000 ppm CO ₂ range	
		5					0 to 5000 ppm CO ₂ range	
Configuration			W				Wall	
CO ₂ Output				4			4 to 20 mA / 0 to (5 or 10) VDC	
Temperature					0		None	
Output					4		4 to 20 mA / 0 to (5 or 10) VDC	
					Α		10 KΩ NTC thermistor type III	
					В		10 KΩ NTC thermistor type II	
					С		3 KΩ NTC thermistor	
					D		Pt100 Ω RTD	
					Е		Pt1000 Ω RTD	
					F		20 KΩ NTC thermistor	
Options						LCD	LCD display	
						RLY	Relay	
						NBC	No buttons	

Figure 8: CDT Model Chart

Series	CDTR	-2	W	4	Α	4	-LCD	Example: CDTR-2W4A4-LCD	
Range		2						0 to 2000 ppm CO ₂ range	
		5						0 to 5000 ppm CO ₂ range	
Configuration			W					Wall	
CO ₂ Output				4				4 to 20 mA / 0 to (5 or 10) VDC	
Temperature					0			None	
Output					Α			10 KΩ NTC thermistor type III	
					В			10 KΩ NTC thermistor type II	
					С			3 KΩ NTC thermistor	
					D			Pt100 Ω RTD	
					E			Pt1000 Ω RTD	
					F			20 KΩ NTC thermistor	
RH Output						4		4 to 20 mA / 0 to (5 or 10) VDC	
Options							LCD	LCD display	
							RLY	Relay	
							NBC	No buttons	

Figure 9: CDTR Model Chart

US Custo	mary Units	SIL	Jnits		
ft	in Hg	m	hPa		
0	29.92	0	1013		
400	29.50	100	1002		
800	29.10	200	990		
1200	28.69	300	979		
1600	28.29	400	968		
2000	27.90	500	957		
2400	27.51	600	946		
2800	27.13	700	935		
3200	26.76	800	924		
3600	26.39	900	914		
4000	26.02	1000	904		
4400	25.66	1100	893		
4800	25.30	1200	883		
5200	24.95	1300	873		
5600	24.60	1400	863		
6000	24.26	1500	853		
6400	23.93	1600	844		
6800	23.60	1700	834		
7200	23.27	1800	824		
7600	22.94	1900	815		
8000	22.63	2000	806		
8400	22.31	2100	797		
8800	22.00	2200	787		
9200	21.70	2300	779		
9600	21.40	2400	770		
10000	21.40	2500	761		

Figure 10: Elevation Chart

RESISTANCE VS TEMPERATURE TABLE

Tempe		Resistance Curves (in Ohms)								
°C	°F	Α	В	С	D	E	F			
-55	-67.0	607800.00	963849.00	289154.70	78.32	783.2	2394000.00			
-50	-58.0	441200.00	670166.00	201049.80	80.31	803.1	1646200.00			
-45	-49.0	323600.00	471985.00	141595.50	82.29	822.9	1145800.00			
-40	-40.0	239700.00	336479.00	100943.70	84.27	842.7	806800.00			
-35	-31.0	179200.00	242681.00	72804.30	86.25	862.5	574400.00			
-30	-22.0	135200.00	176974.00	53092.20	88.22	882.2	413400.00			
-25	-13.0	102900.00	130421.00	39126.30	90.19	901.9	300400.00			
-20	-4.0	78910.00	97081.00	29124.30	92.16	921.6	220600.00			
-15	5.0	61020.00	72957.00	21887.10	94.12	941.2	163500.00			
-10	14.0	47540.00	55329.00	16598.70	96.09	960.9	122280.00			
-5	23.0	37310.00	42327.00	12698.10	98.04	980.4	92240.00			
0	32.0	29490.00	32650.00	9795.00	100.00	1000.0	70160.00			
5	41.0	23460.00	25392.00	7617.60	101.95	1019.5	53780.00			
10	50.0	18780.00	19901.00	5970.30	103.90	1039.0	41560.00			
15	59.0	15130.00	15712.00	4713.60	105.85	1058.5	32340.00			
20	68.0	12260.00	12493.00	3747.90	107.79	1077.9	25360.00			
25	77.0	10000.00	10000.00	3000.00	109.74	1097.4	20000.00			
30	86.0	8194.00	8057.00	2417.10	111.67	1116.7	15892.00			
35	95.0	6752.00	6531.00	1959.30	113.61	1136.1	12704.00			
40	104.0	5592.00	5326.00	1597.80	115.54	1155.4	10216.00			
45	113.0	4655.00	4368.00	1310.40	117.47	1174.7	8264.00			
50	122.0	3893.00	3602.00	1080.60	119.40	1194.0	6722.00			
55	131.0	3271.00	2986.00	895.80	121.32	1213.2	5498.00			
60	140.0	2760.00	2488.00	746.40	123.24	1232.4	4520.00			
65	149.0	2339.00	2083.00	624.90	125.16	1251.6	3734.00			
70	158.0	1990.00	1752.00	525.60	127.08	1270.8	3100.00			
75	167.0	1700.00	1480.00	444.00	128.99	1289.9	2586.00			
80	176.0	1458.00	1255.00	376.50	130.90	1309.0	2166.00			
85	185.0	1255.00	1070.00	321.00	132.80	1328.0	1822.60			
90	194.0	1084.00	915.50	274.65	134.71	1347.1	1540.00			
95	203.0	939.30	786.60	235.98	136.61	1366.1	1306.40			
100	212.0	816.80	678.60	203.58	138.51	1385.1	1112.60			
105	221.0	712.60	587.60	176.28	140.40	1404.0	951.00			
110	230.0	623.60	510.60	153.18	142.29	1422.9	815.80			
115	239.0	547.30	445.30	133.59	144.18	1441.8	702.20			
120	248.0	481.80	389.60	116.88	146.07	1460.7	606.40			
125	257.0	425.30	341.90	102.57	147.95	1479.5	525.60			
130	266.0	376.40	301.00	90.30	149.83	1498.3	N/A			
135	275.0	334.00	265.80	79.74	151.71	1517.1	N/A			
140	284.0	297.20	235.30	70.59	153.58	1535.8	N/A			
145	293.0	265.10	208.90	62.67	155.46	1554.6	N/A			
150	302.0	237.00	186.10	55.83	157.33	1573.3	N/A			

Figure 11: Resistance vs Temperature

www.dwyer-inst.com

e-mail: info@dwyer-inst.com

©Copyright 2013 Dwyer Instruments, Inc.

Printed in U.S.A. 3/13

Phone: 219/879-8000

Fax: 219/872-9057

FR# 06-443800-20 Rev. 1